

SECTION 5

5.13 INTERCONNECTS WITH OTHER WATER SYSTEMS:

Interconnections between Denver Water's treated water system and another Denver Water approved system shall only be allowed in accordance with Section 10.02 of the Board's Operating Rules.

- A. Semi-Permanent Facilities: Where the location of an interconnection can be identified and included in a written agreement between Denver Water and the other party to the interconnection, such facilities shall be constructed in accordance with Sheet 75 and 76 of the Standard Drawings for a dual feed connection and Sheet 77 for a single feed connection. Such facilities shall normally consist of one or more 6 inch lines, each consisting of meter, check valve, and associated piping as detailed in the drawing. No bypass line shall be included. All other provisions of these Engineering Standards shall apply.
- B. Temporary Hose Connections: Where emergency conditions require the use of temporary connections between fire hydrants in order to serve Denver water into another system, such installation shall conform to Sheet 78 of the Standard Drawings. Such conditions shall always include an appropriate meter as described in the drawing.

Activation of interconnections shall be in accordance with Denver Water's standard procedures.